

Annual Drinking Water Quality Report

The Township of Cedar Grove Water Department

Report for the Year 2025, Results from the Year 2024

Following is this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day.

The Township of Cedar Grove Water Department and our suppliers routinely monitor for contaminants in your drinking water according to Federal and State laws. The tables show the results of that monitoring for the period of January 1st to December 31st, 2024. The state allows us to monitor some contaminants less than once per year because the concentration of these contaminants does not change frequently. Some of our data, though representative, is more than one year old.

If you are a landlord, you must distribute this Drinking Water Quality Report to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be made by hand, mail, or email, and by posting the information in a prominent location at the entrance of each rental premises, pursuant to section #3 of NJ P.L. 2021, c.82 (C.58:12A-12.4 et seq.).

Our water supply: In 2024, we purchased our drinking water from the Passaic Valley Water Commission (PVWC) and the North Jersey District Water Supply Commission (NJDWSC). Water Quality test results for the Township of Cedar Grove Water Department, the North Jersey District Water Supply Commission and the Passaic Valley Water Commission are included in this report. Their supply sources are the Passaic River, and the Wanauque and Monksville Reservoir. The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Reports and Summaries for these public water systems, which are included, or are available at <https://www.nj.gov/dep/watersupply/swap/index.html> or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system at 973-239-1410.

Vulnerable Populations: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised people such as people with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Special considerations regarding children, pregnant women, nursing mothers, and others: Children may receive a slightly higher amount of a contaminant present in the water than do adults, on a body weight basis, because they may drink a greater amount of water per pound of body weight than do adults. For this reason, reproductive or developmental effects are used for calculating a drinking water standard if these effects occur at lower levels than other health effects of concern. If there is insufficient toxicity information for a chemical (for example, lack of data on reproductive or developmental effects), an extra uncertainty factor may be incorporated into the calculation of the drinking water standard, thus making the standard more stringent, to account for additional uncertainties regarding these effects. In the cases of lead and nitrate, effects on infants and children are the health endpoints upon which the standards are based.

Township of Cedar Grove Water Department - 2024 Test Results						
PWS ID# NJ0704001						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MCLG	MCL	Likely Source of Contamination
Inorganics:						
Copper Result at 90 th Percentile	N	0.088 No samples exceeded the action level.	Ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead Result at the 90 th Percentile	N	0 No samples exceeded the action level.	Ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products:						
TTHM Total trihalomethanes	N	Range = 34 - 70 Highest LRAA= 63	Ppb	N/A	80	By-product of drinking water disinfection
(HAA5) Total Haloacetic Acids	N	Range = 12 - 60 Highest LRAA = 34	Ppb	N/A	60	By-product of drinking water disinfection

Regulated Disinfectants	Level Detected	MRDL	MRDLG
Chlorine	Range = 0.05 – 1.17 ppm Average = 0.58 ppm	4.0 ppm	4.0 ppm

Chlorine: Water additive used to control microbes.

HAA5 and TTHM compliance is based on the Locational Running Annual Average (LRAA), calculated at each monitoring location. The LRAA calculation is based on four completed quarters of monitoring results.

For additional information: If you have any questions about this report or concerning your water utility, please call Michael Grasso – Water & Sewer Superintendent at 973-239-1410 ext. 282. If you want to learn more, please attend any of our regularly scheduled Town Council Meetings which are held on the First and Third Monday of each month, beginning at 7 p.m., in the Township Council Chambers, Second Floor, 525 Pompton Ave., Cedar Grove, NJ.

DEFINITIONS:

In the “Test Results” tables you may find some terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the contaminant.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or nanogram per liter - one part per trillion corresponds to one minute in 20,000 years, or a single penny in \$100,000,000

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of contaminants in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal -The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Secondary Contaminant- Substances that do not have an impact on health. Secondary Contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

Recommended Upper Limit (RUL) – Recommended maximum concentration of secondary contaminants. These reflect aesthetic qualities such as odor, taste or appearance. RULs are recommendations, not mandates.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

Total Organic Carbon – Total Organ Carbon (TOC) has no health effects. However, TOC provides a medium for the formation of disinfection byproducts. The *Treatment Technique* for TOC requires that 35% - 45% of the TOC in the raw water is removed through the treatment processes.

Turbidity – Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium microbial growth. Turbidity is measured as an indication of the effectiveness of the filtration process. The *Treatment Technique* for turbidity requires that no individual sample exceeds 1 NTU and 95% of the samples collected during the month must be less than 0.3 NTU.

Passaic Valley Water Commission (PVWC) is a major supplier of drinking water in Northern New Jersey. PVWC’s main facility is the Little Falls Water Treatment Plant located in Totowa, NJ. Water diverted from the Passaic and Pompton Rivers is treated, filtered and disinfected at the plant. Treated water is then mixed with treated water from the North Jersey District Water Supply Commission’s Wanaque Reservoir treatment plant.

CRYPTOSPORIDIUM

Cryptosporidium is a microbial pathogen found in surface water throughout the United States. Although filtration removes *Cryptosporidium*, the most commonly used filtration methods cannot guarantee 100 percent removal. Our monitoring indicates the presence of these organisms in our source water. Current test methods do not allow us to determine if the organisms are viable or capable of causing disease. Ingestion of *Cryptosporidium* may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people, infants and small children, and the elderly are at greater risk of developing life-threatening illnesses. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. *Cryptosporidium* must be ingested to cause disease, and it may spread through other means than drinking water. Passaic Valley Water Commission (PVWC) conducted special source *Cryptosporidium* and *Giardia* monitoring in 2020.

North Jersey District Water Supply Commission (NJWSC) 2024 Test Results						
PWS ID #NJ1613001						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants						
Turbidity	N	Highest Measurement 0.619 Range = 0.015 – 0.619 95 % < 0.3	NTU	0	TT 0.3 NTU % of the NTU	Soil runoff
Total Organic Carbon (%)	N	Removal Ratio 1.0 – 1.5 RAA% = 1.2	%	NA	TT = % removal	Naturally present in the environment
PFAS Per- and Polyfluoroalkyl Substances:						
PFOA Perfluorooctane Acid	N	3.63	ppt	N/A	14	Discharge from industrial, chemical, and manufacturing factories, release of aqueous film forming foam.
PFNA Perfluorononanoic Acid	N	< 2.0	ppt	N/A	14	Discharge from industrial, chemical, and manufacturing factories, release of aqueous film forming foam.
PFOS Perfluorooctane Sulfonic Acid	N	2.61	ppt	N/A	13	Discharge from industrial, chemical, and manufacturing factories, release of aqueous film forming foam.

The Table below lists all the drinking water analytes that we detected during calendar year 2024. The presence of these analytes in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from January 1 through December 31, 2024. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

TABLE 1: Table of Detected Contaminants

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers, EPA/CDC guidelines on appropriate means to lessers the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Inorganic Compounds	NJDWSC Result	Min	Max	Result Range	Federal/State MCL	MCLG	MCL Meets Std?	Typical source of Contaminant
Antimony (ppm)	0.000637	----	0.000637	N/A	0.006/0.006	0.006	Yes	Discharge from petroleum refineries; fire retardants, ceramics, electronics, solder.
Barium (ppm)	0.00577	----	0.00577	N/A	2 / 2	2	Yes	
Nickel (ppm)	0.000545	----	0.000545	N/A	N/A	N/A	N/A	
Nitrate (ppm)	0.119	----	0.119	N/A	10 / 10	10	Yes	
Turbidity (NTU) (Combined Filtered Water)	Lowest monthly % of samples <0.3	0.015	0.619	0.015 - 0.619	TT = 1 NTU	Yes	N/A	Soil Runoff
	99.98 %				TT = 95% of samples <0.3 NTU	Yes		
	Average for 2024				0.061 NTU			

Organic Disinfection by-products Annual (Aug 2024)	NJDWSC Result	Min	Max	Result Range	Federal/State MCL	MCLG	MCL Meets Std?	Typical source of Contaminant
Total Trihalomethanes (ppb)	OTP (T2) 28.8 Admin Bldg (P5) 23.5	N/A	28.8 23.5	N/A N/A	80/80	N/A	Yes	By-product of drinking water disinfection
Total Haloacetic Acids (ppb)	OTP (T2) 25.4 Admin Bldg (P5) 18.6	N/A	25.4 18.6	N/A N/A	60/60	N/A	Yes	

Total Organic Carbon (TOC) ppm	TT = Percent (%) removal or meeting alternative criteria removal ratio of	1.2 Running Annual Average (RAA) by % Removal Ratio or Alternative Compliance Criteria Removal Ratio	Percent (%) Removal Range	Removal Ratio Range	Yes	N/A	Naturally present in the environment.
			35.4 - 51.3	1.0 - 1.5			

Regulated Disinfectants NJDWSC Facility	Compliance Met	NJDWSC Results		MRDL	MRDLG	Typical source of Contaminant
		Annual Average	Result Range			
Chlorine as Cl ₂ (ppm)	Yes	1.2	0.72 - 3.58	4.0	4.0	Treatment Process

* Lead & Copper	90th Percentile	AL	Samples > AL	Result Range	MCLG	MCL Meets Std?	Typical source of Contaminant
Lead (ppm)	0.00230	0.015	0	ND - 0.00248	0	Yes	Corrosion of household plumbing; Erosion of natural deposits; Leaching from wood preservatives.
Commission Facility							
Copper (ppm)	0.112	1.3	0	ND - 0.145	1.3	Yes	
Commission Facility							

Lead and Copper: In 2019, NJDWSC qualified for reduced annual monitoring for Lead and Copper per NJDEP. 5 Samples per year (Jun-Sep) NJDWSC's distribution system connections derived from the 4" main service tap, fed from the 84" main line do not contain any lead constituents. (See Lead Service Line (LSL) Information on NJDWSC website and intranet portal.

TABLE 2: SECONDARY PARAMETERS - TREATMENT PLANT EFFLUENT

Secondary Compounds Plant Effluent	NJDWSC Result	Federal/State Secondary Standards (Recommended Upper Limit)	Meet Recommended Standards	Typical source of Contaminant
ABS/LAS	ppm	<0.05	500	yes
Alkalinity	ppm	32.0	NS	yes
Aluminum	ppm	0.0187	≤ 0.200	yes
Chloride	ppm	33.8	≤ 250	yes
Color	CU	2.0	≤ 10	yes
Copper	ppm	0.0218	≤ 1.0	yes
Hardness	ppm	52.0	50 - 250	yes
Iron	ppm	<0.2	≤ 0.3	yes
Manganese	ppm	<0.002	≤ 0.05	yes
Odor	TON	<1	3 TON	yes
Sodium	ppm	22.6	≤ 50	yes
pH	SU	7.93	6.5 - 8.5	yes
Sulfate	ppm	6.14	≤ 250	yes
Total Dissolved Solids	ppm	80	≤ 500	yes
Zinc	ppm	<0.01	≤ 5	yes

Passaic Valley Water Commission 2024 Test Results PWS ID# NJ1605002						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants:						
Turbidity	N	Highest Measurement = 0.135 Range = 0.027 – 0.135 95 % samples < 0.3	NTU	0	TT = % of monthly samples < 0.3 NTU	Soil runoff
Total Organic Carbon (%)	N	Range = 54.65 – 84.84 % Removal range: 35.4-51.3 (25 – 50 % required)		NA	TT = % removal	Naturally present in the environment
Inorganic Contaminants:						
Barium	N	Range = 0.0106 – 0.025 Highest detect = 0.025	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride	N	Range = ND – 0.07 Highest detect = 0.0	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen)	N	Range = 0.53 – 2.91 Highest detect = 2.91	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nickel	N	Range = 1.99 – 2.77 Highest detect = 2.77	ppb	N/A	N/A	Erosion of natural deposits
Combined Radium	N	< 1 (2023 Data)	pCi/L	0	5	Erosion of natural deposits.
PFAS Per- and Polyfluoroalkyl Substances:						
PFOA Perfluorooctane Acid	N	Range = 5.5 – 11.0 Highest detect = 11.0 Highest Average = 8.76	ppt	N/A	14	Discharge from industrial, chemical, and manufacturing factories, release of aqueous film forming foam.
PFOS Perfluorooctane Sulfonic Acid	N	Range = 3.6 – 7.1 Highest detect = 7.10 Highest Average = 5.42	ppt	N/A	13	Discharge from industrial, chemical, and manufacturing factories, release of aqueous film forming foam.
Secondary Contaminant		Level Detected	Units of Measurement		RUL	
Sodium		Range = 40.66 – 103.8	ppm		50	
Odor		Range = 3.0 – 25.0	TON		3	

TABLE 2: SECONDARY PARAMETERS - TREATMENT PLANT EFFLUENT				
Secondary Compounds Plant Effluent	PVWC Result	Federal/State Secondary Standards (Recommended Upper Limit)	Meet Recommended Standards	Typical source of Contaminant
ABS/LAS	ppm	0.08 - 0.140	500	yes
Alkalinity	ppm	N/A	NS	yes
Aluminum	ppm	0.0146 - 0.0251	≤ 0.200	yes
Chloride	ppm	43.5 - 138.5	≤ 250	yes
Color	CU	< 5	≤ 10	yes
Copper	ppm	ND	≤ 1.0	yes
Hardness	ppm	66 - 154	50 - 250	yes
Iron	ppm	<0.1	≤ 0.3	yes
Manganese	ppm	0.00984 - 0.01411	≤ 0.05	yes
Odor	TON	3.0 - 25.0	3 TON	yes
Sodium	ppm	40.66 - 103.88	≤ 50	yes
pH	SU	7.87 - 8.46	6.5 - 8.5	yes
Sulfate	ppm	30.2 - 84.3	≤ 250	yes
Total Dissolved Solids	ppm	172.5 - 445	≤ 500	yes
Zinc	ppm	0.00175 - 0.00364	≤ 5	yes

Naturally present in the environment

PVWC SOURCE WATER PATHOGEN MONITORING

Contaminant	PVWC Plant Intake	Typical Source
<i>Cryptosporidium</i> , Oocysts/L	Range = 0.0 – 0.72	Microbial pathogens found in surface waters throughout the United States.
<i>Giardia</i> , Cysts/L	Range = 0.0 – 0.27	

The Passaic Valley Water Commission exceeded the Recommended Upper Limit for sodium. For healthy individuals, the sodium intake from water is not important, because a much greater intake of sodium takes place from salt in the diet. However, sodium levels above the Recommended Upper Limit (RUL) may be of concern to individuals on a sodium restricted diet.

The Passaic Valley Water Commission exceeded the Recommended Upper Limit for Odor. This was due to chlorine disinfection.

What are PFOA and PFOS?

Perfluorooctanoic acid (PFOA) and perfluorooctane sulfonate (PFOS) are per- and polyfluoroalkyl substances (PFAS), previously referred to as perfluorinated compounds, or PFCs, that are man-made and used in industrial and commercial applications. PFOA was used as a processing aid in the manufacture of fluoropolymers used in non-stick cookware and other products, as well as other commercial and industrial uses based on its resistance to harsh chemicals and high temperatures. PFOS is used in metal plating and finishing as well as in various commercial products. PFOS was previously used as a major ingredient in aqueous film forming foams for firefighting and training, and PFOA and PFOS are found in consumer products such as stain resistant coatings for upholstery and carpets, water resistant outdoor clothing, and grease proof food packaging. Although the use of PFOA and PFOS has decreased substantially, contamination is expected to continue indefinitely because these substances are extremely persistent in the environment and are soluble and mobile in water. More information can be found at: [https://www.state.nj.us/dep/wms/bears/docs/2019-4-15-FAQs_PFOA-PFOS-websites-OLA%204-24-19SDM-\(003\).pdf](https://www.state.nj.us/dep/wms/bears/docs/2019-4-15-FAQs_PFOA-PFOS-websites-OLA%204-24-19SDM-(003).pdf)

Sources of Lead in Drinking Water

The Township of Cedar Grove Water Department and its suppliers are responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. Although most lead exposure occurs from inhaling dust or from contaminated soil, or when children eat paint chips, the U.S. Environmental Protection Agency (USEPA) estimates that 10 to 20 percent of human exposure to lead may come from lead in drinking water. Infants who consume mostly mixed formula can receive 40 percent to 60 percent of their exposure to lead from drinking water. Lead is rarely found in the source of your drinking water but enters tap water through corrosion, or wearing away, of materials containing lead in the water distribution system and household plumbing materials. These materials include lead-based solder used to join copper pipes, brass, and chrome-brass faucets, and in some cases, service lines made of or lined with lead. New brass faucets, fittings, and valves, including those advertised as “lead-free”, may still contain a small percentage of lead, and contribute lead to drinking water. The law currently allows end-use brass fixtures, such as faucets, with up to 0.25 percent lead to be labeled as “lead free”. However, prior to January 4, 2014, “lead free” allowed up to 8 percent lead content of the wetted surfaces of plumbing products including those labeled National Sanitation Foundation (NSF) certified. Visit the NSF website at www.nsf.org to learn more about lead-containing plumbing fixtures. Consumers should be aware of this when choosing fixtures and take appropriate precautions. When water stands in lead service lines, lead pipes, or plumbing systems containing lead for several hours or more, the lead may dissolve into your drinking water. This means the first water drawn from the tap in the morning, or later in the afternoon if the water has not been used all day, can contain fairly high levels of lead.

Steps You Can Take to Reduce Exposure to Lead in Drinking Water

For a full list of steps visit: <https://www.state.nj.us/dep/watersupply/dwc-lead-consumer.html>

Run the cold water to flush out lead. Let the water run from the tap before using it for drinking or cooking any time the water in the faucet has gone unused for more than six hours. The longer the water resides in plumbing the more lead it may contain. Flushing the tap means running the cold-water faucet. Let the water run from the cold-water tap based on the length of the lead service line and the plumbing configuration in your home. In other words, the larger the home or building and the greater the distance to the water main (in the street), the more water it will take to flush properly. Although toilet flushing or showering flushes water through a portion of the plumbing system, you still need to flush the water in each faucet before using it for drinking or cooking. Flushing tap water is a simple and inexpensive measure you can take to protect your health. It usually uses less than one gallon of water.

Use cold, flushed water for cooking and preparing baby formula. Because lead from lead-containing plumbing materials and pipes can dissolve into hot water more easily than cold water, never drink, cook, or prepare beverages including baby formula using hot water from the tap. If you have not had your water sampled or if you know, it is recommended that bottled or filtered water be used for drinking and preparing baby formula. If you need hot water, draw water from the cold tap and then heat it.

Do not boil water to remove lead. Boiling water will not reduce lead; however, it is still safe to wash dishes and do laundry. Lead will not soak into dishware or clothes.

Use alternative sources or treatment of water. You may want to consider purchasing bottled water or a water filter. Read the package to be sure the filter is approved to reduce lead or contact NSF International at 800-NSF-8010 or www.nsf.org for information on performance standards for water filters.

Determine if you have interior lead plumbing or solder. If your home/building was constructed prior to 1987, it is important to determine if interior lead solder or lead pipes are present. You can check yourself, hire a licensed plumber, or check with your landlord.

Replace plumbing fixtures and service lines containing lead. Replace brass faucets, fittings, and valves that do not meet the current definition of “lead free” from 2014 (as explained above). Visit the NSF website at www.nsf.org to learn more about lead-containing plumbing fixtures.

Remove and clean aerators/screens on plumbing fixtures. Over time, particles and sediment can collect in the aerator screen. Regularly remove and clean aerators screens located at the tip of faucets and remove any particles.

Test your water for lead. Please call 973-239-1410 to find out how to get your water tested for lead. Testing is essential because you cannot see, taste, or smell lead in drinking water.

Get your child tested. Contact your local health department or healthcare provider to find out how you can get your child tested for lead if you are concerned about lead exposure. New Jersey law requires that children be tested for lead in their blood at both 1 and 2 years of age and before they are 6 years old if they have never been tested before or if they have been exposed to a known source of lead.

Have an electrician check your wiring. If grounding wires from the electrical system are attached to your pipes, corrosion may be greater. Check with a licensed electrician or your local electrical code to determine if your wiring can be grounded elsewhere. DO NOT attempt to change the wiring yourself because improper grounding can cause electrical shock and fire hazards.

Water softeners and reverse osmosis units will remove lead from water but can also make the water more corrosive to lead solder and plumbing by removing certain minerals; therefore, the installation of these treatment units at the point of entry into homes with lead plumbing should only be done under supervision of a qualified water treatment professional.

Health Effects of Lead

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development. Contact your local health department or healthcare provider to find out how you can get your child tested for lead if you are concerned about lead exposure. You can find out more about how to get your child tested and how to pay for it at <https://www.state.nj.us/health/childhoodlead/testing.shtml>.

In July 2021, P.L.2021, Ch.183 (Law) was enacted, requiring all community water systems to replace lead service lines in their service area within 10 years. Under the law, the Township of Cedar Grove Water Department is required to notify customers, non-paying consumers, and any off-site owner of a property (e.g., landlord) when it is known they are served by a lead service line*. Our service line inventory is available upon request.

Special Notice:

In July 2022; an Updated Drinking Water Service Line Inventory, a Lead Service Line Replacement Plan and an Annual Lead Service Line Replacement Progress Report was to be submitted to the New Jersey Department of Environmental Protection (NJDEP). We were inadvertently late in submitting our Lead Service Line Replacement Plan and our Annual Lead Service Line Replacement Progress Report and received violations reports. Once this information was received by NJDEP, the violations were returned to compliance on 12/21/2022.

Potential sources of contamination: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas projection, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive Contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least some small amounts of contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

SOURCE WATER ASSESSMENT BEFORE TREATMENT:

NJDEP has prepared Source Water Assessment reports and summaries for all public water systems. The Source Water Assessment for the PVWC system (PWS ID 1605002), and NJDWSC system (PWS ID 1613001) can be obtained by accessing NJDEP's source water assessment web site at <http://www.nj.gov/dep/watersupply/swap/index.html> or by contacting NJDEP's Bureau of Safe Drinking Water at 609-292-5550. If a system is rated highly susceptible for a contamination category, it does not mean a customer is – or will be – consuming contaminated water. The rating reflects the potential for contamination of a source of water, not the existence of contamination. Public water systems are required to monitor regulated contaminants and to install treatment if any of those contaminants are detected at frequencies and concentrations above allowable levels. The source water assessments performed on the intakes for each system list the following susceptibility ratings for a variety of contaminants that may be present in source waters:

Intake Susceptibility Ratings	Pathogens	Nutrients	Pesticides	Volatile Organic Compounds	Inorganic Contaminants	Radionuclides	Radon	Disinfection Byproduct Precursors
PVWC 4 Surface Water	4-High	4-High	1-Medium 3-Low	4-Medium	4-High	4-Low	4-Low	4-High
NJDWSC 5 Surface Water	5-High	5-High	2-Medium 3-Low	5-Medium	5-High	5-Low	5-Low	5-High

Pathogens: Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

Nutrients: Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

Volatile Organic Compounds: Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

Pesticides: Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

Inorganics: Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrates.

Radionuclides: Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

Radon: Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.

Disinfection Byproduct Precursors: A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.

Violations

The Cedar Grove Water Department Received NO Violations in 2024.

We at the Township of Cedar Grove Water Department work hard to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions.